

APPENDIX-XI

BUILDING SAFETY CERTIFICATE

No. 126/NC-I/24

Dated: 03/06/2024

Certified that the existing building Saint John School at Banda, Shahjahanpur comprised of basement(s) and Ground Floor & First Floor (upper floors) owned/occupied by Saint John School have compiled with the Building safety requirements in accordance with National Building code Rules. And verified by the officers concerned of Surendra Kumar on 24-05-2024 in the presence of Manager Saint John School, Banda, Shahjahanpur and that the building/premises is fit for occupancy upto classes XII with effect from 24-05-2024 For a period of 23-05-2027 years in accordance with rule and subject to compliance of the specific conditions as appended.

1. 6.00 mt. open area must be required around the building (N.B. Code Part-3 Clause 8.3.1/9)
2. Provision of Earthquake resistance structure drawing (as per Zone-III) must be required.
3. Stair width of building is not less than 1.50 mt. and rise 150 mm. and tread 300 mm. must be required. (N.B. Code Part-3 Clause 12.10)
4. Height of parapet wall of building is not less than 1.00 mt. and not above than 1.20 m. (N.B. Code Part-3 Clause - 12.11)

Issued on at By

❖ Strike out whichever is not applicable.

Signature with Seal :

सहायक अभियन्ता
प्रान्तीय स्तर शासन विभाग

शाहजहाँपुर
Designation : Assistant Engineer

Name & Address of Department/Office : Provincial Division, PWD, Shahjahanpur
(Assistant Engineer & above officer of concerned Govt. Department Only)

Note : This certificate should be signed/ issued by Assistant Engineer & above officer of concerned Govt. Department only.

❖ The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Sr. Priya
PRINCIPAL
SAINT JOHN SCHOOL
Khutar Road, Banda
Dist. Shahjahanpur (U.P.)

Manager
MANAGER
SAINT JOHN SCHOOL
Khutar Road, Banda
Dist. Shahjahanpur (U.P.)